

DVP06XA-S2

Instruction Sheet 安裝說明 安裝說明

Mixed Analog I/O Module

類比I/O混合模組
模擬I/O混合模塊



2014-03-20
5014003700-00XA



Smarter. Greener. Together.

Warning

EN DVP06XA-S2 is an OPEN-TYPE device. It should be installed in a control cabinet free of airborne dust, humidity, electric shock and vibration. To prevent non-maintenance staff from operating DVP06XA-S2, or to prevent an accident from damaging DVP06XA-S2, the control cabinet in which DVP06XA-S2 is installed should be equipped with a safeguard. For example, the control cabinet in which DVP06XA-S2 is installed can be unlocked with a special tool or key.

EN DO NOT connect AC power to any of I/O terminals, otherwise serious damage may occur. Please check all wiring again before DVP06XA-S2 is powered up. After DVP06XA-S2 is disconnected, Do NOT touch any terminals in a minute. Make sure that the ground terminal \ominus on DVP06XA-S2 is correctly grounded in order to prevent electromagnetic interference.

FR DVP06XA-S2 est un module OUVERT. Il doit être installé dans une enceinte protectrice (boîtier, armoire, etc.) saine, dépourvue de poussière, d'humidité, de vibrations et hors d'atteinte des chocs électriques. La protection doit éviter que les personnes non habilitées à la maintenance puissent accéder à l'appareil (par exemple, une clé ou un outil doivent être nécessaire pour ouvrir le protection).


FR Ne pas appliquer la tension secteur sur les bornes d'entrées/Sorties, ou l'appareil DVP06XA-S2 pourra être endommagé. Merci de vérifier encore une fois le câblage lorsque la mise sous tension du DVP06XA-S2. Lors de la déconnection de l'appareil, ne pas toucher les connecteurs dans la minute suivante. Vérifier que la terre est bien reliée au connecteur de terre \ominus afin d'éviter toute interférence électromagnétique.

1 Introduction

Model Explanation & Peripherals


- Thank you for choosing Delta DVP series PLC. DVP06XA-S2 is able to receive 4 points of analog input signals (voltage or current) and convert them into 12-bit/14-bit digital signals. DVP06XA-S2 receives 2 groups of 12-bit digital data from the PLC MPU and converts them into 2 points of analog signals for output (in voltage/current). There are 49 16-bit control registers (CR) in DVP06XA-S2, and the data in it can be read and written by using FROM/TO instructions in DVP Slim series PLC MPU program.
- The user can select voltage or current input by wiring. Range of voltage input: $\pm 10VDC$ (12-bit resolution: 5mV; 14-bit resolution: 1.25mV). Range of current input: $\pm 20mA$ (11-bit resolution: 20 μA ; 13-bit resolution: 5 μA).
- The user can also select voltage or current output by wiring. Range of voltage output: $0V \sim 10VDC$ (default: 12-bit resolution: 2.5mV). Range of current output: $0mA \sim 20mA$ (12-bit resolution: 5 μA).

Product Outline and Terminal Layout



- POWER LED indicator, 1. ERROR LED indicator, 2. Model 3. DIN rail clip 4. Terminals
- Arrangement of the terminals 6. Locating hole on the extension module 7. Nameplate 8. Connector on the extension module
- Mounting clip on the extension module 10. Groove for a DIN rail (35mm) 11. RS-485 port 12. Groove on the extension module
- Power connector 14. Connector on the extension module

External Wiring



- Please isolate the analog input signal cables from other power cables.
- If the module is connected to a current signal, the terminals V4+ and I4+ have to be short-circuited.
- If the ripple in the input voltage results in noise interference with the wiring, please connect the module to the capacitor having a capacitance in the range of $0.1\mu F$ to $0.47\mu F$ with a working voltage of $25V$.
- Please isolate the analog output signal cables from other power cables.
- If the ripple is large for the output terminal of the load and results in noise interference with the wiring, please connect the module to the capacitor having a capacitance in the range of $0.1\mu F$ and $0.47\mu F$ with a working voltage of $25V$.
- Please connect \ominus on a power module and \oplus on DVP06XA-S2 to the ground, and then ground the ground or connect the ground to a distribution box.

Specifications

Mixed analog/digital (A/D) module	Voltage input	Current input
Power supply voltage	24VDC (20.4VDC ~ 28.8VDC) (-15% ~ +20%)	
Analog input channel	4 channels per module	$\pm 20mA$
Analog input range	$\pm 10V$	
Digital data range	$\pm 2,000$ (12 bits); $\pm 8,000$ (14 bits)	$\pm 1,000$ (11 bits); $\pm 4,000$ (13 bits)
Resolution	12 bits ($1_{LSB}=5mV$)	11 bits ($1_{LSB}=20\mu A$)
Input impedance	$200k\Omega$ and above	250Ω
Overall accuracy	$\pm 0.5\%$ of full scale of $25^{\circ}C$ ($77^{\circ}F$). $\pm 1\%$ of full scale during $0 \sim 55^{\circ}C$ ($32 \sim 131^{\circ}F$).	
Response time	3ms \times channels	
Isolation method	Analog circuit is isolated from a digital circuit, but the analog channels are not isolated from one another.	
Absolution input range	$\pm 15V$	$\pm 32mA$
Digital data format	2's complement of a 16-bit value	
Average function	Yes (CR#2 ~ CR#5 can be set and the range is K1 ~ K20)	
Self diagnostic function self detection	Upper bound and lower bound detection per channel	

Mixed digital/analog (D/A) module	Voltage output	Current output
Analog signal output channels	2 channels per module	
Analog output range	$0 \sim 10V$	$\pm 10V$
Digital data range	$0 \sim 4,000$ (12 bits)	$\pm 2,000$ (12 bits)
Resolution	12 bits ($1_{LSB}=5mV$)	12 bits ($1_{LSB}=5mV$)
Overall accuracy	$\pm 0.5\%$ of full scale of $25^{\circ}C$ ($77^{\circ}F$). $\pm 1\%$ of full scale during $0 \sim 55^{\circ}C$ ($32 \sim 131^{\circ}F$).	
Output impedance	0.5Ω or lower	
Response time	3ms \times channels	
Max. output current	$10mA$ ($1k\Omega \sim 2M\Omega$)	—
Tolerance carried impedance	—	$0 \sim 500\Omega$
Digital data format	2's complement of a 16-bit value	
Protection	Voltage output has short circuit protection but long period of short circuit may cause internal damage and current output break.	
Communication mode (RS-485)	MODBUS ASCII/RTU Mode. Communication baud rate of $4,800/9,600/19,200/38,400/57,600/115,200$ bps. For the ASCII mode, date format is 7 bits, even, 1 stop bit (7, E, 1). For the RTU mode, date format is 8 bits, even, 1 stop bit (8, E, 1). The RS-485 is disabled when DVP06XA-S2 is connected in series with MPU.	

CR #	RS-485 parameter address	Latched	Register name	b15 b14 b13 b12 b11 b10 b9 b8 b7 b6 b5 b4 b3 b2 b1 b0
#21	H40DD	<input type="checkbox"/> R/W	To adjust OFFSET value of CH4	CH6 CH5 CH4 CH3 CH2 CH1
#22	H40DE	<input type="checkbox"/> R/W	To adjust OFFSET value of CH5	CH5 CH4 CH3 CH2 CH1
#23	H40DF	<input type="checkbox"/> R/W	To adjust OFFSET value of CH6	CH6 CH5 CH4 CH3 CH2 CH1
#24	H40E0	<input type="checkbox"/> R/W	To adjust GAIN value of CH1	CH1
#25	H40E1	<input type="checkbox"/> R/W	To adjust GAIN value of CH2	CH2
#26	H40E2	<input type="checkbox"/> R/W	To adjust GAIN value of CH3	CH3
#27	H40E3	<input type="checkbox"/> R/W	To adjust GAIN value of CH4	CH4

When users adjust the OFFSET values and the GAIN values of CH1 ~ CH4, they have to note that GAIN value - OFFSET value = 200_{LSB} \sim $3,000_{LSB}$ (voltage) in the 12-bit mode, and GAIN value - OFFSET value = 400_{LSB} \sim $12,000_{LSB}$ in the 14-bit mode. If the value is smaller (steep slope), the resolution of the input signals will be higher, and the variations in digital values will be large. If the value is bigger (gentle slope), the resolution of the input signals will be lower, and the variations in digital values will be slight.

#28 H40E4 R/W To adjust GAIN value of CH5 GAIN setting of CH5 ~ CH6
#29 H40E5 R/W To adjust GAIN value of CH6 The factory setting is K2,000 and the unit is LSB.

When users adjust the OFFSET values and the GAIN values of CH5 ~ CH6, they have to note that GAIN value - OFFSET value = 400_{LSB} \sim $6,000_{LSB}$ (voltage). If the value is smaller (steep slope), the resolution of the input signals will be higher, and the variations in digital values will be large. If the value is bigger (gentle slope), the resolution of the input signals will be lower, and the variations in digital values will be slight.

#30 H40E6 R Error status Data register stores the error status, see error code chart for details.

CR#30 is the error code. Please refer to the chart below.

Error description	Value	b15 b12 b11 b10 b9 b8 b7 b6 b5 b4 b3 b2 b1 b0
The power source is abnormal.	K1 (H1)	0 0 0 0 0 0 0 0 0 0 0 0 0 1
The input exceeds the hardware range.	K2 (H2)	0 0 0 0 0 0 0 0 0 0 0 0 1 0
The setting of the mode is incorrect.	K4 (H4)	0 0 0 0 0 0 0 0 0 0 0 1 0 0
Offset/Gain error	K8 (H8)	0 0 0 0 0 0 0 0 0 0 1 0 0 0
Hardware malfunction	K16 (H10)	0 0 0 0 0 0 0 0 0 1 0 0 0 0
The input signal received by CH1 exceeds the hardware range.	K256 (H100)	0 0 0 1 0 0 0 0 0 0 0 0 0 0
The input signal received by CH2 exceeds the hardware range.	K512 (H200)	0 0 1 0 0 0 0 0 0 0 0 0 0 0
The input signal received by CH3 exceeds the hardware range.	K1024 (H400)	0 1 0 0 0 0 0 0 0 0 0 0 0 0
The input signal received by CH4 exceeds the hardware range.	K2048 (H800)	1 0 0 0 0 0 0 0 0 0 0 0 0 0

Note: Each error code will have a corresponding bit (b0 ~ b11). Two or more errors may happen at the same time. 0 means normal and 1 means having an error.

#31 H40E7 R/W Communication address setting RS-485 communication address.

Setting range is K1 ~ K254 and factory setting is K1.

b0: 4,800 bps (bit/sec)
b1: 9,600 bps (bit/sec) (factory setting)
b2: 19,200 bps (bit/sec)
b3: 38,400 bps (bit/sec)
b4: 57,600 bps (bit/sec)
b5: 115,200 bps (bit/sec)
b6 ~ b13: reserved.
b14: interchanging the low byte and high byte of the CRC code (only for the RTU mode).
b15: ASCII/RTU mode

#32 H40E8 R/W Communication baud rate setting (Unit: bit/second) After H924 is written to CR#32, all the setting values will be restored to the factory settings.

Hexadecimal value

#33 H40E9 R/W Restoring DVP06XA-S2 to the factory settings

After H924 is written to CR#33, all the setting values will be restored to the factory settings.

#34 H40EA R System version

The current system version is displayed.

Example: H101A=Version 1.0A.

System used

#35 ~ #48 Symbols: means latched. R means can read data by using FROM instruction or RS-485. means non-latched. W means can write data by using TO instruction or RS-485.

LSB Least Significant Bit:

1. Voltage input: $1_{LSB}=10V/2,000=5mV$ (12 bits); $1_{LSB}=10V/8,000=1.25mV$ (14 bits)

2. Current input: $1_{LSB}=20mA/1,000=20\mu A$ (11 bits); $1_{LSB}=20mA/4,000=5\mu A$ (13 bits)

3. Voltage output: $1_{LSB}=10V/4,000=2.5mV$ (12 bits)

4. Current output: $1_{LSB}=20mA/4,000=5\mu A$ (12 bits)


*: The corresponding parameters address H40C8 ~ H40EA of CR#0 ~ CR#34 will allow user to read/write data via RS-485. Function code: 03H - read data from register. 06H - write one word into register. 10H - write multiple words into registers.

RS-485 Function code: 03H - read data from register. 06H - write one word into register. 10H - write multiple words into registers.

RS-485 Function code: 03H - read data from register. 06H - write one word into register. 10H - write multiple words into registers.

RS-485 Function code: 03H - read data from register. 06H - write one word into register. 10H - write multiple words into

#1	H'40C9	O R/W	输入/输出模式設定	<p>輸入模式設定 (CH1 ~ CH4) :</p> <p>模式 0 : 電壓輸入模式 (-10V ~ +10V)</p> <p>模式 1 : 電壓輸入模式 (-6V ~ +10V)</p> <p>模式 2 : 電流輸入模式 (-12mA ~ +20mA)</p> <p>模式 3 : 電流輸入模式 (-20mA ~ +20mA)</p> <p>模式 7 : 不使用</p> <p>輸出模式設定 (CH5 ~ CH6) :</p> <p>模式 0 : 電壓輸出模式 (0V ~ 10V) - 模式 1: 電壓輸出模式 (2V ~ 10V) - 模式 2: 電流輸出模式 (4mA ~ 20mA) - 模式 3: 電流輸出模式 (0mA ~ 20mA)</p> <p>CR#1 : b0 ~ b11 內容值用來設定類比信號輸入 (AD) 部份四個通道的工作模式，每個通道各有四種模式，可獨立設定。例如要將 CH1 ~ CH4 分別輸入設定為 CH1 : 模式 0 (b2 ~ b0=000) - CH2 : 模式 1 (b5 ~ b3=001) - CH3 : 模式 2 (b8 ~ b6=010) - CH4 : 模式 3 (b11 ~ b9=011) 時，須將 b0 ~ b11 設為 H'688 - b12 ~ b15 內容值用來設定類比信號輸出 (DA) 部份兩個通道的工作模式，每個通道各有四種模式，可獨立設定。例如要將 CH5 ~ CH6 分別輸出設定為 CH5 : 模式 2 (b13 ~ b12=10) - CH6 : 模式 1 (b15 ~ b14=01) - 須將 b12 ~ b15 設為 H'6，出廠設定為 H'0000。</p> <p>#2 H'40CA O R/W CH1 平均次數</p> <p>#3 H'40CB O R/W CH2 平均次數</p> <p>#4 H'40CC O R/W CH3 平均次數</p> <p>#5 H'40CD O R/W CH4 平均次數</p> <p>#6 H'40CE x R CH1 輸入信號平均值</p> <p>#7 H'40CF x R CH2 輸入信號平均值</p> <p>#8 H'40D0 x R CH3 輸入信號平均值</p> <p>#9 H'40D1 x R CH4 輸入信號平均值</p> <p>#10 H'40D2 x R/W CH5 輸出數值</p> <p>#11 H'40D3 x R/W CH6 輸出數值</p> <p>#12 H'40D4 x R CH1 輸入信號現在值</p> <p>#13 H'40D5 x R CH2 輸入信號現在值</p> <p>#14 H'40D6 x R CH3 輸入信號現在值</p> <p>#15 H'40D7 x R CH4 輸入信號現在值</p> <p>#16 H'40D8 x R/W DA : ±10V AD : 12/14 位元切換 (出廠值 H'0000)</p> <p>#18 H'40DA O R/W CH1 微調 OFFSET 值</p> <p>#19 H'40DB O R/W CH2 微調 OFFSET 值</p> <p>#20 H'40DC O R/W CH3 微調 OFFSET 值</p> <p>#21 H'40DD O R/W CH4 微調 OFFSET 值</p> <p>#22 H'40DE O R/W CH5 微調 OFFSET 值</p>
----	--------	-------	-----------	--



② 規格

模擬數字 (AD) 部分	電壓輸入	電流輸入
电源电压	24VDC (20.4VDC ~ 26.4VDC) (-15% ~ +10%)	
模拟信号输入通道	4 通道/台	
模拟输入范围	±10V	±20mA
数字转换范围	±2,000 (12 位) ±8,000 (14 位)	±1,000 (11 位) ±4,000 (13 位)
解析度	1 _{LSB} =5mV (12 位) 1 _{LSB} =1.25mV (14 位)	1 _{LSB} =5μA (11 位) 1 _{LSB} =5μA (13 位)
输入阻抗	200kΩ 以上	250Ω
总和精度	±0.5% 在 (25°C ~ 77°F) 范圍內滿刻度時。	±1% 在 (0 ~ 55°C ~ 32 ~ 131°F) 范圍內滿刻度時。
响应时间	3ms × 通道数	
隔离方式	数字电路与模拟电路之间有隔离，模拟通道间未隔离。	
绝对输入范围	±15V	±32mA
数字数据格式	16 位元二补数	
平均功能	有 (CR#2 ~ CR#5 可设定 - 范围 K1 ~ K20)	
自我诊断功能	上下极限侦测/通道	
数字/模拟 (DA) 部分	电压输出	电流输出
模拟信号输出通道	2 通道/台	
模拟输出范围	0 ~ 10V	0 ~ 20mA
数字数据范围	0~4,000 (12 位)	±2,000 (12 位)
解析度	1 _{LSB} =2.5mV (12 位) 1 _{LSB} =5mV (12 位)	1 _{LSB} =5μA (12 位)
总和精度	±0.5% 在 (25°C ~ 77°F) 范圍內滿刻度時。	±1% 在 (0 ~ 55°C ~ 32 ~ 131°F) 范圍內滿刻度時。
响应时间	3ms × 通道数	
输出阻抗	0.5Ω or 更低	
容许负载阻抗	10mA (1kΩ ~ 2MΩ)	-
数字数据格式	16 位元二补数	
保护	电压输出有短路保护但須注意長時間短路仍有可能造成內部線路损坏电流输出可开路。	
通讯模式 (RS-485)	有包含 ASCII/RTU 模式 通讯速率可选 4,800/9,600/19,200/38,400/57,600/115,200 数据格式固定为 7 位元、偶位、1 stop bit (7, E, 1) * RTU 模式数据格式固定为 8 位元、偶位、1 stop bit (8, E, 1) * 当 PLC 主机串接时 - RS-485 通讯无法使用。	
与 DVP-PLC 主机串接说明	模块编号以靠近主机的顺序自动编号由 0 到 7 最大可连接 8 台且不占用数字 I/O 点数。	

#20	H'40DC	O R/W	CH3 微調 OFFSET 值	
#21	H'40DD	O R/W	CH4 微調 OFFSET 值	
#22	H'40DE	O R/W	CH5 微調 OFFSET 值	
#23	H'40DF	O R/W	CH6 微調 OFFSET 值	
#24	H'40E0	O R/W	CH1 微調 GAIN 值	
#25	H'40E1	O R/W	CH2 微調 GAIN 值	
#26	H'40E2	O R/W	CH3 微調 GAIN 值	
#27	H'40E3	O R/W	CH4 微調 GAIN 值	
#28	H'40E4	O R/W	CH5 微調 GAIN 值	
#29	H'40E5	O R/W	CH6 微調 GAIN 值	
#30	H'40E6	x R	錯誤狀態	儲存所有錯誤狀態的資料暫存器，詳細內容請參照錯誤信息表。
#31	H'40E7	O R/W	RS-485 通訊地址設定	設定 RS-485 通訊地址，設定範圍 01 ~ 254，出廠設定為 K1。
#32	H'40E8	O R/W	Baud rate 設定	設定通訊速率，共有 4,800 / 9,600 / 19,200 bps / 38,400 bps / 57,600 bps / 115,200 bps 六種。ASCII 模式数据格式固定为 7 位元、偶位、1 stop bit (7, E, 1) * RTU 模式数据格式固定为 8 位元、偶位、1 stop bit (8, E, 1) * b6 ~ b13 : 保留
#33	H'40E9	O R/W	恢復出厂設定	寫入 HF924 時 - 所有設定值將回復為原廠設定值。
#34	H'40EA	O R	系統版本	16 進制 - 顯示目前系統版本，如 1.0A 則 H'010A。

